

Tender No: DMRC/Elec /IT&PD/ ILBS/ Hostel- 04

Addendum-1 to Tender Documents

Sr. No	Chapter Ref.	Page No	Topic & Clause No	Location	Amendments / Remarks
1	2	3	4	5	6
(A) Volume—1 : Notice Inviting Tender (NIT) , Instructions To Tenderers(ITT) , Special Conditions of Contract (SCC) & DMRC Labour Welfare Rules					
1	ITT	47 of 56	Letter of Under Taking (Ref:clause 9.1.2-c page 10 of 56)	Whole Format of page 47	Deleted --- “Letter of Under taking” --whole Format of page 47 deleted. Added: ‘ New Format of “ <u>Letter of Under taking</u> ” with form T-iii added as “Annexure—A of Addendum-1 page 47-R of 56” of ITT.
(B) Volume—2 : Special Specification					
2	Spl.Spec	59 of 114	“ <u>Rating Details</u> ” (Ref:clause 3-vi page 59 of 114)	End of line after “rated current”	Deleted --- “85 ⁰ C” deleted Added: “ 90⁰ C ”
3	Spl.Spec	60 of 114	“Enclousers” (Ref:clause-12.4 page 60 of 114)	18 th line (after The bus duct should be--)	Deleted --- “IP-55” deleted Added: “ IP-54 ”
4	Spl. Spec	72 of 114	‘Sand witch Bus Duct.’ List of Approved make/Manufacturer (Clause 14 item Sr..no-27)	item Sr.no-27page 72	Make Newly Added (additional) “Control &switch Gear”
5	Spl.Spec	70 of 114	‘Butterfly Valve ’ List of Approved make/Manufacturer (Clause 14 item Sr..no-4)	item Sr.no-4 page 70	Make Newly Added (additional) “Advance”
6	Spl.Spec	71 of 114	‘Flow Meter for Oil Piping’ List of Approved make/Manufacturer (Clause 14 item Sr.. 13no-)	item Sr.no-13 page 71	Make Newly Added (additional) “Japsin”
Sr. No	Chapter Ref.	Page No	Topic & Clause No	Location	Amendments / Remarks

1	2	3	4		6
(C) Volume—4 : BOQ					
7	Part –A (Electrical Work) Section-1	3 of13	Bus Duct sub Item1.4	Last Line	Deleted --- “IP-52” deleted <u>Added:</u> <u>“IP-54”</u>
8	Part –A (Electrical Work) Section-11	11 of13	SITC Air COOLER Item13.6	Last Line After “low input Voltage”	<u>Added:</u> In Last Line After low input Voltage Added: “ <u>18 inch dia. , 960 rpm with electronic regulator</u>”
(D) Volume-1 (Annexure-1 of ITT) Initial Filter(PQ)					
9	Initial Filter PT-III	39 of 47	Assesment Topics-“ T10-DG set ”	Second line at last	Deleted --- “of total 1500 Kva” <u>Added:</u> “of total 1000 Kva”

ANNEXURE-A OF ADDENDUM-I

LETTER OF UNDERTAKING

(On Tenderer's Letter Head to be submitted with Form T-III)

Date

To

The Managing Director

Delhi Metro Rail Corporaion Limited

13,Fire brigade lane,

Barakhamba Road,

New Delhi-110001

Supply,Re-location, Installation, Testing, Commissioning and Handing over of Electrical , Fire Fighting , Hot Water Solar System works and Relocation of Chimney & External Fire Ring Main Works of Nurses & Interns Hostel-Blocks of ILBS (Institute of Liver& Biliary Science) at D-1 Basant Kunj, New Delhi-110070."

1. We Hereby confirm that if we are considered to award this contract, we shall follow all the terms and conditions of DMRC for deployment of Project Personals (i.e. staff for work execution and staff for SHE) as mentioned in ITT Form T-III and in tender Document.

1. We Confirm that minimum requirement of Project Personals as mentioned in ITT Form T-III will be deployed and staff will be experts of requisite experience & qualification (minimum graduate in engineering with minimum 15 years experience as project Manager for Project Manager s and minimum 5 years experience of relevant discipline for other engineers) will be mobilized by us for the work in addition to semiskilled & skilled staff.

2. **We also confirm that this is minimum project specific mobilization and these will be suitably augmented , as required for achieving the tender requirements and key dates.**

Signed-----

For and on behalf of

(Name of Tenderer/Joint Venture)