

Tender No:DMRC/ELECT./IT&PD/ILBS/EL/01**Addendum-3 to Tender documents**

Sr. No.	Chapter Ref.	Page No.	Topic & Clause No.	Location	Amendments/Remarks
1	2	3	4	5	6
(A) Volume-2: Specification (Electrical Works) & Volume-4 (Bill of Quantities)					
1	Volume-2 , Specification	37 of 157	Clause 2.13.5.1 Moulded Case Circuit Breaker , General	4 th para	Deleted : “MCCB shall be available in plug-in version in 3-pole and 4-pole versions.” & replaced with “MCCB shall be available in plug-in version in 3-pole and 4-pole versions for Totally Type Tested Assembly (TTA) type of panels only. ” This is a Mandatory Requirement for Totally Type Tested Assembly (TTA) type of panels only The above change is applicable wherever appearing in this Tender.
2	Volume-2 , Specification	38 of 157	Clause 2.13.5.2 Moulded Case Circuit Breaker , Construction , Operation, Environment	2 nd para (on page 38)	Deleted :- ‘Isolation shall be provided by a double break on the main circuit’ & replaced with ‘Isolation shall preferably be provided by a double break on the main circuit’.
3	Volume-2 , Specification	40 of 157	Clause 2.13.5.27 Moulded Case Circuit Breaker , Microprocessor Trip Units	Before Load Monitoring Function	Added :- ‘The above mentioned characteristics if vary, according to Approved Manufacturers Standards shall be accepted subject to approval of Engineer-In-Charge’