

Tender No:DMRC/ELECT./IT&PD/ILBS/HVAC-LV-FF/02

Addendum-5 to Tender documents

Sr. No.	Chapter Ref.	Page No.	Topic & Clause No.	Location	Amendments/Remarks
1	2	3	4	5	6
(A) Volume-2: Specification (HVAC, LV & Fire Fighting Works)					
1	Volume-2 , HVAC Specification	16 of 204	Section 2.0 , Chillers	Subsection 2.1, (Water Cooled Screw Chillers) Compressors ,1st Line	Deleted : "compressors with twin screw rotors". & to be replaced as " compressors with screw rotors".
2	Volume-2 , HVAC Specification	18 & 20 of 204	Section 2.0 , Chillers	Subsection 2.1 & 2.2, (Water Cooled Screw Chillers) & (Multipurpose Chiller) At the End	Added : 'The Contractor/Manufacturer shall have to produce Performance Certificates for Satisfactory Running & Operation over Last 5 years of the proposed Chillers from their respective clients/clients as proposed by DMRC , at the time of Technical/Vendor Approval

Note :-

1. The Date of Tender Submission and Technical Package Opening is further extended as under :-
 - a. Revised Date of Submission of Tender :- **24-01-2012 upto 1430 hrs**
 - b. Revised Date of Opening of Technical Package (along with PQ) :- **24-01-2012 at14:35 hrs.**
2. Addendum-5 to be read in conjunction with Tender Documents and all previous Addendums/Corrigendums issued so far by this office.
3. All other Terms and conditions remain unchanged.